



WATER-BASED SUPPRESSION PLAN REVIEW SUBMITTAL

CITY OF LACONIA FIRE PREVENTION DIVISION
848 NORTH MAIN STREET, LACONIA, NH 03246
Call (603) 524-6881 for appointments and information

**FIRE
PREVENTION
Suppression**

500-2-C

January 2017

This checklist pertains to the information needed to review the water-based fire suppression systems.

The following information is required:

General:

- Project Description
- Complete Name of the Owner or Occupant (not the installer)
- Physical Address of Project
- Mailing Address (of the owner/occupant)
- Type of Construction
- Occupancy Classification

System:

- Engineers seal and stamp (13D systems may use NICET-III in lieu of engineer stamp)
- Specification sheets on all devices, attachments, piping and sprinkler heads (two sets)
- System hydraulic calculations (two sets)
- Provide two (2) Sets of floor plans with full height of the hazard being protected
- Provide the location and type of all bracing and hangers
- Provide the location and type of all seismic bracing on piping 2.5" in diameter and greater
- Provide the location of any special hazards
- Provide the location of all inspectors test sites
- Provide the location of the FDC (4")
- Provide the method of connection to the building fire alarm system where applicable

For engineered systems, a statement on the plans reading "There shall be no deviation from the plans without approval from the Authority Having Jurisdiction."